

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:44 am

PWS ID: UTAH04001 **Name:** ASPEN VIEW-SCOFIELD MOUNTAIN HOMES
Legal Contact: ASPEN VIEW-SCOFIELD MT HM **Rating:** Approved
SCOTT MCBRIDE **Rating Date:** 10/26/2010
Address: 339 SOUTH 1400 EAST **Activity Status:** Active
SPANISH FORK, UT 84660
Phone Number: 435-798-6661
City Served (Area):
County: CARBON COUNTY

System Type: Non-community **Last Inv Update:** 07/13/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/25/2008 **Total Dsgn Cap:**
Population: 100 **Surveyor:** SEAN R JORDAN **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	MCBRIDE, SCOTT		801-798-6661		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	90
			90 Total Svc Connections

Storage

Total Storage: 49,000 GAL **Number of Units:** 7 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST006	20000 GALLON WATER TANK #2	Underground	20,000 GAL	Fiberglass		A	NO
ST007	9000 GALLON WATER TANK	Ground	9,000 GAL	Fiberglass		A	NO
ST005	20000 GALLON WATER TANK #1	Ground	20,000 GAL	Fiberglass		A	NO
ST001	7500 GALLON WATER TANK	Ground		Steel		I	NO
ST002	6000 GALLON WATER TANK	Ground	9,000 GAL	Fiberglass		I	NO
ST003	42000 GALLON WATER TANK	Ground		Steel		I	NO
ST004	10000 GALLON WATER TANK	Ground	13,625 GAL	Concrete		I	NO

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	ANDREW DAIRY SPRING	Inactive	SP				Yes	GW	Other	1/1 to 12/31	
WS002	TUCKER CANYON SPRING	Inactive	SP				Yes	GW	Other		
WS003	FRANDSEN WELL	Active	WL	6	30 GPM	20 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.